A Nationally Accredited Police Department

## ANNUAL FIRE LOG: 2021

Building Name N/A	Fire Number N/A	Reported/C Date N/A	Occurrence Time(s) N/A	Location N/A	Cause of Fire N/A	o Injuries <sup>1</sup>	o Deaths <sup>2</sup>	Damages <sup>3</sup>
Pritchard Hall	2021-00 001810	01/28/2021- 01/29/2021	0100-1000	Fifth Floor	Burnt Cardstock/burnt mark on wall	0	0	\$0.00
Hoge Hall	2021-00 002591	02/09/2021	2144	Second Floor	Grease fire	0	0	\$0.00
Slusher Hall	2021-00 007565	04/20/2021	2011	Ninth Floor	Electrical Hazard/evidence of burning	0	0	\$0.00
Newman Hall	2021-00 010357	06/11/2021	1940	First Floor	Rags around insulation on exhaust pipes	0	0	\$0.00
Hoge Hall	2021-00 019676	11/08/2021- 11/09/2021	1900-1945	Seventh Floor	Burn marks on cork bulletin board	0	0	\$0.00
New Residence Hall East	2021-00 019765	11/10/2021	2045	Third Floor	Computer Battery fire	0	0	\$0.00
East Ambler Johnson	2021-00 020058	11/14/2021	0043-0130	First Floor	Blower Motor for Exhaust Fan/Access Panel	0	0	\$0.00

<sup>&</sup>lt;sup>1</sup>Number of injuries that required treatment at a medical facility. <sup>2</sup>Number of deaths related to the fire. <sup>3</sup>Value of property damage caused by the fire.